



**District Level Water Analysis Laboratory**  
**Uttar Pradesh Jal Nigam, (Rural)**  
**Fatehpur (212601)**



**TC-12419**

TEST REPORT (WATER)

Report N C:	FTP/JAN/3484	Date:	24/01/2024
<b>Customer details</b>			
Office Name and Address:	Children Public Senior Secondary School Fatehpur Uttar Pradesh 212601		
<b>Basic details of sample</b>			
District:	Fatehpur	Block:	Teliyani
Gram Panchayat / Town :	Nasirpur	Village/ City:	Fatehpur
Habitation:	Fatehpur	Location:	Jail Road Fatehpur
Water Source:	Handpump	Sample no:	01
Quantity of Sample:	2.0 Litter	Date of S.C.:	23/01/2024
Receiving Date:	23/01/2024	S. Collector:	ANURAG KUMAR
Sample Depositor:	ANURAG KUMAR		
Analysis Start Date:	24/01/2024	Analysis Completion Date:	24/01/2024

S.No.	Analysed Parameters	Observe	Specified Values as Per BIS 10500:2012		Ref. Method Of Analsis
			Acceptable Limit	Permissible	
	2	3	4	5	6
1	PH*	7.37	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2012 (Electrometric Method)
2	Turbidity (NTU)*	0.68	1	5	Is 3025 (Part 10):2012
3	Chloride (Mg/L)*	28	250	1000	Is 3025 (Part 32): 2014
4	Total Alkalinity (Mg/L)*	134	200	600	Is 3025 (Part 23): 2008
5	Total Hardness (Mg /L)*	240	200	200	Is 3025 (Part 21): 2009
6	Fluoride*	0.77	1	1.5	Is 3025 (Part 60): 2008 (Elect Chem. Probe Meth.)
7	Calcium (as Ca)*	140	75 mg/L	200 mg/L	<b>IS 3025 (Part 40): 2019</b>
8	Magnesium (as Mg)*	80	30 mg/L	100 mg/L	<b>IS 3025 (Part 46): 2019</b>
9	TDS	718	500	2000	IS 3025 (Part 16): 2023
10	IRON (AS Fe)*	0.16	1	No Relaxation	<b>IS 3025 (Part 53): 2019</b>
11	Sulphates*	16	200	400	<b>IS 3025 (Part 24/Sec 1): 2019</b>
12	Nitrate*	06	45	No Relaxation	<b>IS 3025 (Part 34) : 1988</b>

- Note
- \*Indicates parameters that are NABL accredited.
  - this test results related to the sample tested above.
  - the report shall not be reproduced in full without approval of authority.
  - this is the end of the report.

REPORT PREPARED- BY- Anuj Kumar

Authorized Signatory  
Sandeep Kumar

S.K.

**Principal**  
**Children Public Sr. Sec. School**  
**Fatehpur**  
 Affn. No-2130597

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY**

**CONDITION CERTIFICATE**

No.-----

Date: 14/03/24

It is certified that an inspection team headed by Dr. ----- Chief Medical Officer, Fatehpur (Name of officers with designation) from District Hospital Fatehpur (Name of Department Officer) inspected the CHILDREN PUBLIC SR. SEC. SCHOOL ,CHITRANSH NAGAR, FATEHPUR (U.P.) (Name & Address of the school) on ----- and found that the CHILDREN PUBLIC SR. SEC. SCHOOL ,CHITRANSH NAGAR, FATEHPUR (U.P.) (Name of school) has safe drinking water facilities for the students and members of staff of the instruction and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/ State/ U.T. govt.

The above valid for the period from-----to-----

डि० दयानंद  
M.B.B.S.M.S.Orho  
अतिरिक्त सर्जन  
फतेहपुर - उत्तर प्रदेश

डि० दयानंद  
M.B.B.S.M.S.Orho  
अतिरिक्त सर्जन  
फतेहपुर - उत्तर प्रदेश

Signature with seal:-----  
Name DR. DAYANAND  
Designation Orho Surgeon

To,

MANAGER  
Children Public Sr. Sec. School ,  
Chitransh Nagar - Fatehpur (U.P.)  
(Name & Address of the Institution)

  
Principal  
Children Public Sr. Sec. School  
Fatehpur  
Affn. No-2130597